



Sertifikat o kontrolisanju
Inspection certificate

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1710

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser: **IMMERGAS, S.p.A., Via Cisa Ligure 95 42041 Brescello RE**
Italija/Italy

preduzeto je/
has been undertaken: kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report: Broj / Number: T 1710

sa dokumentima u prilogu/
with attached documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaj o ispitivanju Kiwa broj 130601391; / Test report
by Kiwa No. 130601391

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
subject of the inspection: **GASNI KOTAO**
GAS BOILER

proizveden od /
manufactured by : **IMMERGAS, S.p.A., Via Cisa Ligure 95 42041 Brescello RE**
Italij

oznaka - tip - serija /
mark - type - series : **VICTRIX TERA ...**

vrsta/type: C_{13(x)}, C_{33(x)}; B₃₃
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document : **SRPS EN 15502-2-1: 2013**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012.

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

20.04.2022.

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
LABORATORIJA
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781 029
impcgt@pupin.rs

izdat od / issued by :
MIHAJLO PUPIN
BEGRAD
S.P.
BEGRAD
RUKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER
Kristina Petković, M.Sc.M.E.

mesto, datum / place, date **Beograd, 20.04.2017.**

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1710

Strana / Page:

2/2

Prilog A /
Annex A

oznaka - tip - serija /
 mark - type - series :

VICTRIX TERA ...

vrsta/type: C_{13(x)}, C_{33(x)}; B₃₃
 kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
VICTRIX TERA...		
...28 1	Q _n =4,5 ÷ 24,6 kW Q _n =4,5 ÷ 28,8 kW *) P _n =4,3 ÷ 24,1 kW P _n =4,3 ÷ 28,3 kW *)	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
...32 1	Q _n =5,1 ÷ 28,6 kW Q _n =5,1 ÷ 32,6 kW *) P _n =4,9 ÷ 28,0 kW P _n =4,9 ÷ 32,0 kW *)	
...24 PLUS	Q _n =4,5 ÷ 24,6 kW Q _n =4,5 ÷ 28,8 kW *) P _n =4,3 ÷ 24,1 kW P _n =4,3 ÷ 28,3 kW *)	
Napomene / notes: *) za / for: TSV/DHW		

Sertifikat o kontrolisanju
Inspection certificate