



Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPa / Type examination

Broj / Number: T 2020

POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: **P.V.F. TRADERS DOO BEOGRAD Vodovodska 158
Beograd Srbija/Srbija**

preduzeto je/
has been undertaken: **Kontrolisanje novog proizvoda
Inspection of the new product**

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number: T 2020

sa dokumentima u prilogu/
with attached documents: - Uputstvo za instaliranje, održavanje i korisnika /
Installation, maintenance instructions and User manual;
- Dokumentacija ugrađenih komponenti / Documentation of embedded components;
- Izveštaj o ispitivanju IMP-CGT T 1409 / Test report T 1409

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI MODULI ZA POSTAVLJANJE NA
OTVORENOM PROSTORU / GAS MODULES
DESIGNED FOR OUTDOOR INSTALLATION**

proizveden od /
manufactured by: **IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)
Italija / Italy**

oznaka - tip - serija /
mark - type - series: **VICTRIX PRO BLOCK 70 - 600**

vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /

The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 27. 05. 2020. - 12.06.2020.

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum izdavanja /
place, date of issue:

Beograd, 12.06.2020



Ime, Prezime / Name, Surname



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs



Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

SERTIFIKAT

O PREGLEDU TIPa/ Type examination

POJEDINAČNI PREGLED/Single examination

Prilog A /
Annex A

Broj / Number:

T 2020

Strana / Page:

2 / 2

oznaka - tip - serija /
mark - type - series :

VICTRIX PRO BLOCK ...

vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija mark - type - series specification :	tehničke karakteristike / technical characteristics :		kratak opis / short description :
	broj i model kotla VICTRIX PRO ... 1l u modulu / number and model of the boiler VICTRIX PRO ... 1l in the module	toplotna snaga modula / heat output of the module min / max [kW]	
... 70	2 x 35	3,4 ÷ 68	samo za grejanje / for heating only
... 105	3 x 35	3,4 ÷ 102	
... 110	2 x 55	5,0 ÷ 100	
... 140	4 x 35	3,4 ÷ 136	
... 160	2 x 80	7,2 ÷ 146	
... 165	3 x 55	5,0 ÷ 150	
... 175	5 x 35	3,4 ÷ 170	
... 200	2 x 100	9,0 ÷ 180	
... 220	4 x 55	5,0 ÷ 200	
... 240	2 x 120	11,0 ÷ 222	
	3 x 80	7,2 ÷ 219	
... 275	5 x 55	5,0 ÷ 250	
... 300	3 x 100	9,0 ÷ 270	
... 320	4 x 80	7,2 ÷ 292	
... 360	3 x 120	11,0 ÷ 333	
... 400	4 x 100	9,0 ÷ 360	
	5 x 80	7,2 ÷ 365	
... 480	4 x 120	11,0 ÷ 444	
... 500	5 x 100	9,0 ÷ 450	
... 600	5 x 120	11,0 ÷ 555	

Napomena: Ovaj Sertifikat koristiti zajedno uz Sertifikat o pregledu tipa broj T 1914. / This Certificate to be used together with the Certificate of Type T 1914.

Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. / Any changes on the device must be reported to the issuer of this document