



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 0929
Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser: FONDERIE SIME S.p.A.,
Legnago (VR), Italija/Italy

preduzeto je/
set to: kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 0929

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 0929 /
Test report by IMP-CGT-LAB No. T 0929

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object: GASNI KOTAO
GAS BOILER

proizveden od /
manufactured by: FONDERIE SIME S.p.A.,
Legnago (VR), Italija/Italy

oznaka - tip - serija /
mark - type - series: SIME METROPOLIS DGT ... BF

vrsta/type: C₁₂, C₃₂, C₄₂, C₅₂
kategorija/category: II_{2H3B/P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements as described in:

referentnom dokumentu /
reference document: EN 483:1999 ; SRPS EN 625:1999

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002 .
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

06.10.2014

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 2772 151
fax: +381 11 2781 029
impogt@labtel.imp.bg.ac.rs

mesto, datum / place, date: M.P. /

Beograd, 07.10.2009



izdat od / issued by :
RUKOVODIOCA CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

Mr. Vladeta Buljak, dip. ing.

Ime, Prezime / Name, Surname



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 0929

Strana / Page: 2/2

Prilog A /

Annex A

oznaka - tip - serija /
mark - type - series :

SIME METROPOLIS DGT ... BF

vrsta/type: C₁₂, C₃₂, C₄₂, C₅₂
kategorija/category: II_{2H3B/P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
SIME METROPOLIS DGT...			
... 25 BF	Q _n =9,2÷25,5 kW Hi P _n =7,5÷23,7 kW	2H: p=20 mbar 3B/P: p=30 mbar PMS=3 bar, T=80°C 230 V, 50 Hz,	zidni gasni kotao sa pripremom tople sanitarne vode /
... 30 BF	Q _n =10,8÷30,0 kW Hi P _n =9,0÷28,0 kW	IP X5D NO _x : 3 η : ★★★	wall hung gas boiler with domestic hot water preparation

Sertifikat o kontrolisanju
Inspection certificate

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 2772 151
fax: +381 11 2781 029
impcgt@labtei.imp.bg.ac.rs