



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1228

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser: **Vaillant GmbH- Predstavništvo u Srbiji ,**
Radnička 59, Beograd, Srbija/Serbia

preduzeto je/
set to: kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 1228

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1228 /
Test report by IMP-CGT-LAB No. T 1228.

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object : **GASNI PROTOČNI ZAGREJAČ VODE/**
GAS BURNING APPLIANCE FOR INSTANTANEOUS
PRODUCTION OF HOT WATER

proizveden od /
manufactured by : **Vaillant GmbH, Berghauser Strasse 40**
42859 Remscheid, Nemačka/Germany

oznaka - tip - serija /
mark - type - series : **VAILLANT turbo MAG SOE...**

vrsta/type: C₁₂, C₃₂, C₄₂
kategorija/category: II_{2H3B/P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements sa decribed in :

referentnom dokumentu /
reference document : **SRPS EN 26:2009.**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002 .
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa periodičnim
kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical inspection
until the date :

11.07.2017.

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 2772 151
fax: +381 11 2781 029
impcgt@labtel.imp.bg.ac.rs

izdat od / issued by :
RUKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER
mesto, datum / place, date: **M.P. /**
S.P.
Beograd, 12.07.2012. mr. Vladeta Buljak, dipl. ing.

Ime, Prezime / Name, Surname

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: **T 1228**

Strana / Page: **2/2**

Prilog A /
Annex A

oznaka - tip - serija /
 mark - type - series :

VAILLANT turbo MAG SOE...

vrsta/type: **C₁₂, C₃₂, C₄₂**
 kategorija/category: **II_{2H3B/P}**

detaljno oznaka - tip - serija / mark - type - series specification :			tehničke karakteristike / technical characteristics :		kratak opis / short description :
VAILLANT turbo MAG SOE...					
... turbo MAG SOE	11	2/0	Q _n =11,1÷22,6 kW P _n =8,6÷19,5 kW	2H: p=20 mbar 3B/P: p=30 mbar PMW= 13 bar	- za pripremu tople sanitarne vode (TSV) / - for domestic hot water preparation (DHW)
	14	2/0	Q _n =11,1÷26,9 kW P _n =8,6÷23,7 kW	230V, 50 Hz	

Inspection certificate

Sertifikat o kontrolisanju