



<b>QUALITY CERTIFICATE</b> <b>EN 10204 / 3.1</b>	REPORT NO			
	DATE	16.04.2019		
	CLIENT	P.V.F.TRADERS D.O.O.- DYV2019000000133		
<b>NAME OF PRODUCT</b>				
TYPE OF VALVE		BALL VALVE		
NOMINAL DIAMETER ( DN ) mm		DN 100 DN 065		
NOMINAL PRESSURE (PN) bar		PN 16		
STANDARD / DESIGN		TS 3148, EN ISO 17292		
END CONNECTION		BS EN 1092-2		
QUANTITY		61		
Nominal Diameter		QUANTITY	QUANTITY	
DN 100		20 PCS		
DN 065		41 PCS		
<b>SPECIFICATION OF MATERIALS</b>				
Body	EN JL 1040 (GG 25)	O-Ring	EPDM	
Flange	EN JL 1040 (GG 25)			
Lever	St 37 (ÇELİK)			
Stem	AISI 420 (STAINLESS STEEL)			
Ball	STAINLESS STEEL			
Seals	PTFE			
<b>TEST CONDITIONS</b>				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
<b>TYPICAL CHEMICAL ANALYSIS</b>				
C	Mn	Si	P	S
3,12	0,49	2,07	0,045	0,042
INSIDE CLEANING	OK			
PAINTING&COLOR	BLUE			
END COVER	OK			
MARKING				
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE MANAGER / Aykut ÖZMAN		