



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

22.03.2019

CLIENT

P.V.F.TRADERS D.O.O.-
DYV2019000000094

NAME OF PRODUCT

TYPE OF VALVE

STATIC BALANCING VALVE

NOMINAL DIAMETER (DN) mm

DN 050 DN 080

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS EN 13789

END CONNECTION

BS EN 1092-2

QUANTITY

9

Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY
DN 050	4 PCS		
DN 080	5 PCS		

SPECIFICATION OF MATERIALS

Body	EN JL 1040 (GG 25)
Bonnet	EN JL 1040 (GG 25)
Handwheel	EBONITE
Disc	EN JS 1030 (GGG 40) + RUBBER COATED
Measurement probe	CuZn40Pb2 (BRASS)
Stem	AISI 420 (STAINLESS STEEL)

TEST CONDITIONS

TEST LIQUID	WATER
BODY TEST	24 BAR
LEAKAGE TEST	18 BAR
TEST STANDART NO	TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C	Mn	Si	P	S
3,12	0,45	2,1	0,0433	0,046

INSIDE CLEANING	OK
PAINTING&COLOR	BLACK
END COVER	OK
MARKING	OK

INSPECTOR / Zafer KUVVET

QUALITY ASSURANCE MANAGER / Aykut ÖZMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST.

Tel: 0212 444 82 62 Fax: 0212 355 07 47

Marmara Kurumlar VD : 320 003 9012

DVF-20-047

DUYAR