



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO			
	DATE	16.04.2019		
	CLIENT	P.V.F.TRADERS D.O.O.- DYV2019000000133		
NAME OF PRODUCT				
TYPE OF VALVE	Y TYPE STRAINER			
NOMINAL DIAMETER (DN) mm	DN 100 DN 065 DN 065			
NOMINAL PRESSURE (PN) bar	PN 16			
STANDARD / DESIGN	TS 11494			
END CONNECTION	TS EN 1092-2			
QUANTITY	43			
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 100	15 PCS			
DN 065	18 PCS			
DN 065	10 PCS			
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)			
Bonnet	EN JL 1040 (GG 25)			
Filter	AISI 304 (STAINLESS STEEL)			
Gasket	KLINGERIT			
Plug Gasket	COPPER			
Plug	Si 37 (STEEL)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,12	0,51	2,09	0,032	0,038
INSIDE CLEANING	OK			
PAINTING&COLOR	BLUE			
END COVER	OK			
MARKING	OK			
INSPECTOR / Zafer KUVVET	QUALITY ASSURANCE MANAGER / Aykut ÖZMAN			

DVF 20-047