



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	1024/2017			
	DATE	10.11.2017			
	CLIENT	P.V.F. TRADERS D.O.O.			
NAME OF PRODUCT					
TYPE OF VALVE		BALL VALVE			
NOMINAL DIAMETER (DN) mm		DN 040 DN 025 DN 032 DN 125 DN 040 DN 050			
NOMINAL PRESSURE (PN) bar		PN 16			
STANDARD / DESIGN		TS 3148, EN ISO 17292			
END CONNECTION		BS EN 1092-2			
QUANTITY		85			
Nominal Diameter		QUANTITY	Nominal Diameter	QUANTITY	
DN 040		10 PCS			
DN 025		10 PCS			
DN 032		10 PCS			
DN 125		5 PCS			
DN 040		30 PCS			
DN 050		20 PCS			
SPECIFICATION OF MATERIALS					
Body	EN JL 1040 (GG 25)	O-Ring	EPDM		
Flange	EN JL 1040 (GG 25)				
Lever	St 37 (ÇELİK)				
Stem	AISI 420 (STAINLESS STEEL)				
Ball	STAINLESS STEEL				
Seals	PTFE				
TEST CONDITIONS					
TEST LIQUID	WATER				
BODY TEST	24 BAR				
LEAKAGE TEST	18 BAR				
TEST STANDART NO	TS EN 12266-1				
TYPICAL CHEMICAL ANALYSIS					
C	Mn	Si	P	S	Zn
3,12	0,49	2,07	0,045	0,042	39,41
CONTROL FOR DISPATCH					
INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar Y.D.: 320 003 6012 Mersis No: 0320003901200011			
PAINTING&COLOR	BLUE				
END COVER	OK				
MARKING	OK				
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN			



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

22.12.2017

CLIENT

P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE

BALL VALVE

NOMINAL DIAMETER (DN) mm

DN 040

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS 3148, EN ISO 17292

END CONNECTION

BS EN 1092-2

QUANTITY

40

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 040

40 PCS

SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

O-Ring

EPDM

Flange

EN JL 1040 (GG 25)

Lever

St 37 (ÇELİK)

Stem

AISI 420 (STAINLESS
STEEL)

Ball

STAINLESS STEEL

Seals

PTFE

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,12

0,49

2,07

0,045

0,042

INSIDE CLEANING

PAINTING&COLOR

END COVER

MARKING

OK

BLUE

OK

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST

Tel: 0212 444 82 62 Fax: 0212 355 07 47

Marmara Kurumlar Y.D: 320 003 9012

Mersis No: 0320003901200011

INSPECTOR /

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

DVF-20-047

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

23.11.2017

CLIENT

P.V.F. TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE

BALL VALVE

NOMINAL DIAMETER (DN) mm

DN 050 DN 065 DN 080 DN 100

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS 3148, EN ISO 17292

END CONNECTION

BS EN 1092-2

QUANTITY

120

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 050

50 PCS

DN 065

10 PCS

DN 080

40 PCS

DN 100

20 PCS

SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

O-Ring

EPDM

Flange

EN JL 1040 (GG 25)

Lever

St 37 (ÇELİK)

Stem

AISI 420 (STAINLESS
STEEL)

Ball

STAINLESS STEEL

Seals

PTFE

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,12

0,49

2,07

0,045

0,042

INSIDE CLEANING

PAINTING&COLOR

END COVER

MARKING

OK

BLUE

OK

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.
Osmangazi Mh. 2653 Sk. No:7/1 Kırac-Esenyurt / İSİT
Tel: 0212 444 82 62 Fax: 0212 355 07 47
Marmara Kurumlar V.D.: 320 003 9012
Mersis No: 0320003991200011

INSPECTOR /

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

DVF 20-047

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAC / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve



QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO	1024/2017			
		DATE	10.11.2017			
		CLIENT	P.V.F.TRADERS D.O.O.			
NAME OF PRODUCT						
TYPE OF VALVE		BALL VALVE				
NOMINAL DIAMETER (DN) mm		DN 200				
NOMINAL PRESSURE (PN) bar		PN16				
STANDARD / DESIGN		TS 3148,EN ISO 17292				
END CONNECTION		TS EN 1092-2				
QUANTITY		7				
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY			
DN 200	7 PCS					
SPECIFICATION OF MATERIALS						
Body	EN JL 1040 (GG 25)	Packing	PTFE			
Flange	EN JL 1040 (GG 25)	O-Ring	EPDM			
Lever	St 37 (Steel)					
Ball	Stainless Steel					
Stem	AISI 420 (STAINLESS STEEL)					
Seals	PTFE					
TEST CONDITIONS						
TEST LIQUID	WATER					
BODY TEST	24 BAR					
LEAKAGE TEST	18 BAR					
TEST STANDART NO	TS EN 12266-1					
TYPICAL CHEMICAL ANALYSIS						
C	Mn	Si	P	S	Zn	
3,15	0,49	2,07	0,045	0,042		39,41
CONTROL FOR DISPATCH						
INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kırac Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar V.D.: 328 003 5 012 Mersis No: 0320003281200011				
PAINTING&COLOR	BLUE					
END COVER	OK					
MARKING	OK					
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN				