


QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO		
		DATE	20.07.2018	
		CLIENT	P.V.F. TRADERS D.O.O.	
NAME OF PRODUCT				
TYPE OF VALVE		SPRINKLER SIDEWALL		
NOMINAL DIAMETER (DN) mm		DN 015 DN 015		
NOMINAL PRESSURE (PN) bar		PN 12		
STANDARD / DESIGN		TS EN 12259-1		
END CONNECTION		ISO 7/1		
QUANTITY		470		
Nominal Diameter		QUANTITY	QUANTITY	
DN 015		300 PCS		
DN 015		170 PCS		
SPECIFICATION OF MATERIALS				
Body	CuZn40Pb2 (Ms 58)			
Bulb slot	CuZn40Pb2 (Ms 58)			
Bulb	Glass+Liquid			
Packing	Be - Ni Alloy + Teflon Coated			
Deflector	Stainless Steel (CF 8)			
Grub	Stainless Steel (CF 8)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	34,5 BAR			
LEAKAGE TEST	34,5 BAR			
TEST STANDART NO	TS EN 12845 + A2			
TYPICAL CHEMICAL ANALYSIS				
Mn	Cu	Pb	Sn	Zn
0,04	57,4	2,71	0,038	39,41
INSIDE CLEANING	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmangazi Mah. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar Y.D.: 320 003 9012 Mersis No: 0320003901200011			
PAINTING&COLOR				
END COVER				
MARKING				
INSPECTOR / Zafer KUVVET	QUALITY ASSURANCE MANAGER / Aykut ÖZMAN			