



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

3.08.2018

CLIENT

P.V.F. TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE

NOMINAL DIAMETER (DN) mm

NOMINAL PRESSURE (PN) bar

STANDARD / DESIGN

END CONNECTION

QUANTITY

SPRINKLER SIDEWALL

DN 015

PN 12

TS EN 12259-1

ISO 7/1

30

Nominal Diameter

DN 015

QUANTITY

30 PCS

Nominal Diameter

QUANTITY

SPECIFICATION OF MATERIALS

Body

CuZn40Pb2 (Ms 58)

Bulb slot

CuZn40Pb2 (Ms 58)

Bulb

Glass+Liquid

Packing

Be - Ni Alloy + Teflon Coated

Deflector

Stainless Steel (CF 8)

Grub

Stainless Steel (CF 8)

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

34,5 BAR

LEAKAGE TEST

34,5 BAR

TEST STANDART NO

TS EN 12845 + A2

TYPICAL CHEMICAL ANALYSIS

Mn

0,04

Cu

57,4

Pb

2,71

Sn

0,038

Zn

39,41

INSIDE CLEANING

OK

PAINTING&COLOR

END COVER

MARKING

OK

INSPECTOR / Zafer KUVVET

QUALITY ASSURANCE MANAGER / Aykut ÖZMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.
Osmanlı Mah. 2653 Sok. No:7/1 Kiraç-Esenyurt / İST.
Tel: 0212 444 82 62 Fax: 0212 355 07 47
Marmara Kurumları A.Ş. 340 063 001
Mersis No: 32000000000000000000



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

3.08.2018

CLIENT

P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE

SPRINKLER SIDEWALL

NOMINAL DIAMETER (DN) mm

DN 015

NOMINAL PRESSURE (PN) bar

PN 12

STANDARD / DESIGN

TS EN 12259-1

END CONNECTION

ISO 7/1

QUANTITY

31

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 015

31 PCS

SPECIFICATION OF MATERIALS

Body

CuZn40Pb2 (Ms 58)

Bulb Ssolt

CuZn40Pb2 (Ms 58)

Bulb

Glass + Liquid

Packing

Be-Ni Alloy + Teflon Coated

Deflector

Paslanmaz Çelik (CF 8)

Grub

Stainless Steel (CF 8)

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

34,5 BAR

LEAKAGE TEST

34,5 BAR

TEST STANDART NO

TS EN 12845 + A2

TYPICAL CHEMICAL ANALYSIS

Mn

Cu

Pb

Sn

Zn

0,04

57,4

2,71

0,038

39,41

INSIDE CLEANING

OK

PAINTING&COLOR

END COVER

MARKING

OK

INSPECTOR / Zafer KUVVET

QUALITY ASSURANCE MANAGER / Aykut ÖZMAN

DUYAR

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

Osmangazi Mh. 2653 Sk. No:7/1 KIRIÇ-ESENYURT / İST.

Tel: 0212 444 82 62 Fax: 0212 255 07 47


Marmara Kurumlar Y.D.: 320 001 0032

Marsis: 330 020 0001 0000 0000 0000 0000 0000

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.
OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRIÇ / ESENYURT / İSTANBUL - TÜRKİYE
TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DVF 20-047

QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO		
		DATE	20.07.2018	
		CLIENT	P.V.F. TRADERS D.O.O.	
NAME OF PRODUCT				
TYPE OF VALVE		SPRINKLER SIDEWALL		
NOMINAL DIAMETER (DN) mm		DN 015		
NOMINAL PRESSURE (PN) bar		PN 12		
STANDARD / DESIGN		TS EN 12259-1		
END CONNECTION		ISO 7/1		
QUANTITY		69		
Nominal Diameter		QUANTITY		
DN 015		69 PCS		
SPECIFICATION OF MATERIALS				
Body	CuZn40Pb2 (Ms 58)			
Bulb Ssolt	CuZn40Pb2 (Ms 58)			
Bulb	Glass + Liquid			
Packing	Be-Ni Alloy + Teflon Coated			
Deflector	Paslanmaz Çelik (CF 8)			
Grub	Stainless Steel (CF 8)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	34,5 BAR			
LEAKAGE TEST	34,5 BAR			
TEST STANDART NO	TS EN 12845 + A2			
TYPICAL CHEMICAL ANALYSIS				
Mn	Cu	Pb	Sn	Zn
0,04	57,4	2,71	0,038	39,41
INSIDE CLEANING	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar V.D.: 320 003 9012 Mersis No: 032000390120001			
PAINTING&COLOR				
END COVER				
MARKING				
INSPECTOR / Zafer KUVVET	QUALITY ASSURANCE MANAGER / Aykut ÖZMAN			