



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO			
	DATE	31.05.2018		
	CLIENT	P.V.F.TRADERS D.O.O.		
NAME OF PRODUCT				
TYPE OF VALVE	METAL SEATED GATE VALVE			
NOMINAL DIAMETER (DN) mm	DN 050 DN 065 DN 080			
NOMINAL PRESSURE (PN) bar	PN 16			
STANDARD / DESIGN	TS EN 1171			
END CONNECTION	BS EN 1092-2			
QUANTITY	80			
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 050	40 PCS			
DN 065	20 PCS			
DN 080	20 PCS			
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)	Gasket	EPDM	
Bonnet	EN JL 1040 (GG 25)			
Handwheel	EN JL 1040 (GG 25)			
Wedge	EN JL 1040 (GG 25)			
Stem	AISI 420 (STAINLESS STEEL)			
Seats	CuZn40Pb2 (BRASS)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,12	0,48	2,08	0,05	0,042
INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmanгази Mh. 2653 Sok. No: 7/1 KIRIÇ-ESENYURT / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumları V.D. 1320-003 0012 Mersis No: 0370103911200011		
PAINTING&COLOR	BLUE			
END COVER	OK			
MARKING	OK			
INSPECTOR / Zafer KUVYET	QUALITY ASSURANCE MANAGER / Aykut ÖZMAN			