



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

21.11.2018

CLIENT

P.V.F. TRADERS D.O.O.-
DYV201800000549

NAME OF PRODUCT

TYPE OF VALVE

OS&Y METAL SEATED GATE VALVE

NOMINAL DIAMETER (DN) mm

DN 080

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS EN 1171

END CONNECTION

BS EN 1092-2

QUANTITY

4

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 080

4 PCS

SPECIFICATION OF MATERIALS

Body

EN JS 1030 (GGG 40)

Handwheel

EN JL 1040 (GG 25)

Bonnet

EN JS 1030 (GGG 40)

Wedge

EN JS 1030 (GGG 40)

Stem

AISI 420

Seat

CuZn40Pb2

Gasket

EPDM

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

12 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,75

0,13

2,47

0,005

0,012

INSIDE CLEANING

PAINTING&COLOR

OK

END COVER

BLACK

MARKING

OK

INSPECTOR / Zafer KUVVET

QUALITY ASSURANCE MANAGER / Aykut ÖZMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZİ MAH.2653 SOK. NO :7 /1 KIRIÇ / ESENYURT / İSTANBUL - ÜRKEK

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmanlı Mah. 2653 Sok. No:7/1 Kırıç-Esenyurt / İST.

ÜRKEK Tel: 0212 444 82 62 Fax: 0212 355 07 47

Marmara Kurumlar V.D.: 320 003 9012

Mersis No: 0320003901200011



QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO	946	
		DATE	18.09.2018	
		CLIENT	P.V.F.TRADERS D.O.O. DYV2018000000453	
NAME OF PRODUCT				
TYPE OF VALVE		OS&Y METAL SEATED GATE VALVE		
NOMINAL DIAMETER (DN) mm		DN 080 DN 100		
NOMINAL PRESSURE (PN) bar		PN 16		
STANDARD / DESIGN		TS EN 1171		
END CONNECTION		BS EN 1092-2		
QUANTITY		9		
Nominal Diameter		QUANTITY		
DN 080		4 PCS		
DN 100		5 PCS		
SPECIFICATION OF MATERIALS				
Body	EN JS 1030 (GGG 40)	Handwheel	EN JL 1040 (GG 25)	
Bonnet	EN JS 1030 (GGG 40)	Gasket	EPDM	
Wedge	EN JS 1030 (GGG 40)			
Stem	AISI 420			
Seat	CuZn40Pb2			
Gasket	EPDM			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	12 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,75	0,13	2,47	0,005	0,012
INSIDE CLEANING	OK			
PAINTING&COLOR	OK			
END COVER	BLACK			
MARKING	OK			
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE MANAGER / Aydin ÖZMA		



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

31.05.2018

CLIENT

P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE

OS&Y METAL SEATED GATE VALVE

NOMINAL DIAMETER (DN) mm

DN 080 DN 150 DN 100

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS EN 1171

END CONNECTION

BS EN 1092-2

QUANTITY

9

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 080

2 PCS

DN 150

2 PCS

DN 100

5 PCS

SPECIFICATION OF MATERIALS

Body

EN JS 1030 (GGG 40)

Handwheel

EN JL 1040 (GG 25)

Bonnet

EN JS 1030 (GGG 40)

Wedge

EN JS 1030 (GGG 40)

Stem

AISI 420

Seat

CuZn40Pb2

Gasket

EPDM

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

12 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,75

0,13

2,47

0,005

0,012

INSIDE CLEANING

PAINTING&COLOR

OK

END COVER

BLACK

MARKING

OK



DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmanгази Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST.

Tel: 0212 444 82 62 Fax: 0212 355 07 47

Marmara Kurumlar V.D.: 320 003 9017

Mersis No: TR 20013901200011

INSPECTOR / Zeynep KUVVET

QUALITY ASSURANCE MANAGER / Veysel ATILGAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DVF-20-047