



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	814/2018		
	DATE	12.01.2018		
	CLIENT	P.V.F.TRADERS D.O.O.		
NAME OF PRODUCT				
TYPE OF VALVE	STATIC BALANCING VALVE			
NOMINAL DIAMETER (DN) mm	DN 050 DN 065 DN 100 DN 125			
NOMINAL PRESSURE (PN) bar	PN 16			
STANDARD / DESIGN	TS EN 13789			
END CONNECTION	BS EN 1092-2			
QUANTITY	22			
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 050	5 PCS			
DN 065	10 PCS			
DN 100	5 PCS			
DN 125	2 PCS			
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)			
Bonnet	EN JL 1040 (GG 25)			
Handwheel	EBONITE			
Disc	EN JS 1030 (GGG 40) + RUBBER COATED			
Measurement probe	CuZn40Pb2 (BRASS)			
Stem	AISI 420 (STAINLESS STEEL)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,12	0,45	2,1	0,0433	0,046
INSIDE CLEANING				
PAINTING&COLOR	OK			
END COVER	BLACK			
MARKING	OK			
INSPECTOR /Tamer SOYDAN		DUYAR QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN		
DUYAR VANA MAKİNA SAN. ve TİC. A.Ş. Osmancazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar V.D.: 320 003 9012 Mersis No: 0320003901200011				

DVF-20-047