



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO	1024/2017
DATE	28.7.2017
CLIENT	P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE	CHECK VALVE WITH SPRING
NOMINAL DIAMETER (DN) mm	DN 200 DN 125 DN 150
NOMINAL PRESSURE (PN) bar	PN 16
STANDARD / DESIGN	TS EN 12334
END CONNECTION	TS EN 1092-2
QUANTITY	11

Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY
DN 200	3 PCS		
DN 125	3 PCS		
DN 150	5 PCS		

SPECIFICATION OF MATERIALS

Body	EN JL 1040 (GG 25)	Seat	AISI 304 (Stainless Steel)
Bonnet	EN JL 1040 (GG 25)	Gasket	Klingelit
Spring	AISI 302 (Stainless Steel)		
Stem DN125..300	AISI 302 (Stainless Steel)		
Stem DN15..100	EN JL 1040 (GG 25)		
Disc	AISI 420 (Stainless Steel)		

TEST CONDITIONS

TEST LIQUID	WATER
BODY TEST	24 BAR
LEAKAGE TEST	18 BAR
TEST STANDART NO	TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C	Mn	Si	P	S	Zn
3,1	0,53	2,07	0,04	0,043	39,41

CONTROL FOR DISPATCH

INSIDE CLEANING	OK
PAINTING&COLOR	BLUE
END COVER	OK
MARKING	OK

INSPECTOR / Tamer SOYDAN

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO : 7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DVF 20-047