



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	765/2016
	DATE	3.02.2017
	CLIENT	P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE	Y TYPE STRAINER
NOMINAL DIAMETER (DN) mm	DN 020 DN 125 DN 150
NOMINAL PRESSURE (PN) bar	PN 16
STANDARD / DESIGN	TS 11494
END CONNECTION	TS EN 1092-2
QUANTITY	25

Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY
DN 020	10 PCS		
DN 125	10 PCS		
DN 150	5 PCS		

SPECIFICATION OF MATERIALS

Body	EN JL 1040 (GG 25)	Lever	St 37 (STEEL)
Bonnet	EN JL 1040 (GG 25)	Spring	AISI 302 (STAINLESS STEEL)
Filter	AISI 304 (STAINLESS)	Bonnet Extension	CuZn40Pb2 (BRASS)
Gasket	KLINGERIT	Sight Glass	ACRYLIC
Plug Gasket	COPPER	Sight Glass Gasket	EPDM
Plug	St 37 (STEEL)	Label Plate	AISI 304 (STAINLESS STEEL)

TEST CONDITIONS

TEST LIQUID	WATER
BODY TEST	24 BAR
LEAKAGE TEST	18 BAR
TEST STANDART NO	TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C	Mn	Si	P	S
3,12	0,51	2,09	0,032	0,038

CONTROL FOR DISPATCH

INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. ve TİC. A.Ş. Osmanlı Mah. 2653 Sk. No:7/1 Kırcağ-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar V.D.: 320 003 9012 Mersis No: 0320003901200011
PAINING&COLOR	BLUE	
END COVER	OK	
MARKING	OK	

INSPECTOR / Tamer SOYDAN

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DVF 20-047