



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	764/2016
	DATE	3.02.2017
	CLIENT	P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE	BALL VALVE
NOMINAL DIAMETER (DN) mm	DN 100 DN 040 DN 065
NOMINAL PRESSURE (PN) bar	PN 16
STANDARD / DESIGN	TS 3148, EN ISO 17292
END CONNECTION	BS EN 1092-2
QUANTITY	38

Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY
DN 100	10 PCS		
DN 040	20 PCS		
DN 065	8 PCS		

SPECIFICATION OF MATERIALS

Body	EN JL 1040 (GG 25)	O-Ring	EPDM
Flange	EN JL 1040 (GG 25)	Spring	AISI 302 (STAINLESS STEEL)
Lever	St 37 (ÇELİK)	Bonnet Extension	CuZn40Pb2 (BRASS)
Stem	AISI 420 (STAINLESS STEEL)	Sight Glass	ACRYLIC
Ball	STAINLESS STEEL	Sight Glass Gasket	EPDM
Seals	PTFE	Label Plate	AISI 304 (STAINLESS STEEL)

TEST CONDITIONS

TEST LIQUID	WATER
BODY TEST	24 BAR
LEAKAGE TEST	18 BAR
TEST STANDART NO	TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C	Mn	Si	P	S
3,12	0,49	2,07	0,045	0,042

CONTROL FOR DISPATCH

INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. ve TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kırcağ-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar Y.D.: 320 003 9012 Mersis No: 0320009901200011
PAINTING&COLOR	BLUE	
END COVER	OK	
MARKING	OK	

INSPECTOR / Tamer SOYDAN

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DVF 20-047