



QUALITY CERTIFICATE EN 10204 / 3.1

REPORT NO	899/2017
DATE	26.4.2017
CLIENT	P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE	GLOBE VALVE
NOMINAL DIAMETER (DN) mm	DN 200 DN 040 DN 050 DN 050
NOMINAL PRESSURE (PN) bar	PN 16
STANDARD / DESIGN	TS EN 13789
END CONNECTION	TS EN 1092-2
QUANTITY	85

Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY
DN 200	5 PCS		
DN 040	50 PCS		
DN 050	2 PCS		
DN 050	28 PCS		

SPECIFICATION OF MATERIALS

Body	EN JL 1040 (GG 25)
Flange	EN JL 1040 (GG 25)
Handwheel	EN JL 1040 (GG 25)
Stem	AISI 420 (STAINLESS STEEL)
Disc	AISI 420 (STAINLESS STEEL)
Seat	AISI 304 (STAINLESS STEEL)

TEST CONDITIONS

TEST LIQUID	WATER
BODY TEST	24 BAR
LEAKAGE TEST	18 BAR
TEST STANDART NO	TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C	Mn	Si	P	S
3.12	0.56	2.1	0.041	0.043

CONTROL FOR DISPATCH

INSIDE CLEANING	OK
PAINTING&COLOR	BLUE
END COVER	OK
MARKING	OK

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.
Ölçü Birimi: Mm. 2653 Sok. No: 7/1 KIRIÇ-ESENYURT / İST.
Tel: 0212 444 82 62 Fax: 0212 355 07 47
Marmara Kurumlar V.D.: 329 003 9012
Mersis No: 0320003901200011

INSPECTOR / Tamer SOYDAN

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRIÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DVF 20-047