



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	901/2017		
	DATE	26.4.2017		
	CLIENT	P.V.F.TRADERS D.O.O.		
NAME OF PRODUCT				
TYPE OF VALVE		Y TYPE STRAINER		
NOMINAL DIAMETER (DN) mm		DN 050 DN 200 DN 080 DN 065 DN 025 DN 040		
NOMINAL PRESSURE (PN) bar		PN 16		
STANDARD / DESIGN		TS 11494		
END CONNECTION		TS EN 1092-2		
QUANTITY		73		
Nominal Diameter		QUANTITY	Nominal Diameter	QUANTITY
DN 050		10 PCS		
DN 200		3 PCS		
DN 080		20 PCS		
DN 065		20 PCS		
DN 025		10 PCS		
DN 040		10 PCS		
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)			
Bonnet	EN JL 1040 (GG 25)			
Filter	AISI 304 (STAINLESS)			
Gasket	KLINGERIT			
Plug Gasket	COPPER			
Plug	St 37 (STEEL)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,12	0,51	2,09	0,032	0,038
CONTROL FOR DISPATCH				
INSIDE CLEANING	OK			
PAINTING&COLOR	BLUE			
END COVER	OK			
MARKING	OK			
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN		