



QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO	1024/2017			
		DATE	10.11.2017			
		CLIENT	P.V.F. TRADERS D.O.O.			
NAME OF PRODUCT						
TYPE OF VALVE		BALL VALVE				
NOMINAL DIAMETER (DN) mm		DN 040 DN 025 DN 032 DN 125 DN 040 DN 050				
NOMINAL PRESSURE (PN) bar		PN 16				
STANDARD / DESIGN		TS 3148, EN ISO 17292				
END CONNECTION		BS EN 1092-2				
QUANTITY		85				
SPECIFICATION OF MATERIALS						
Body	EN JL 1040 (GG 25)	O-Ring	EPDM			
Flange	EN JL 1040 (GG 25)					
Lever	St 37 (ÇELİK)					
Stem	AISI 420 (STAINLESS STEEL)					
Ball	STAINLESS STEEL					
Seals	PTFE					
TEST CONDITIONS						
TEST LIQUID	WATER					
BODY TEST	24 BAR					
LEAKAGE TEST	18 BAR					
TEST STANDART NO	TS EN 12266-1					
TYPICAL CHEMICAL ANALYSIS						
C	Mn	Si	P	S	Zn	
3,12	0,49	2,07	0,045	0,042		39,41
CONTROL FOR DISPATCH						
INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar Y.D.: 320 003 5012 Mersis No: 0320003901200011				
PAINTING&COLOR	BLUE					
END COVER	OK					
MARKING	OK					
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN				