



QUALITY CERTIFICATE		REPORT NO	599/2016	
EN 10204 / 3.1		DATE	18.10.2016	
		CLIENT	P.V.F.TRADERS D.O.O.	
NAME OF PRODUCT				
TYPE OF VALVE		DUAL PLATE CHECK VALVE		
NOMINAL DIAMETER (DN) mm		DN 150 DN 100		
NOMINAL PRESSURE (PN) bar		PN 16		
STANDARD / DESIGN		TS EN 12234		
END CONNECTION		TS EN 1092-2		
QUANTITY		14		
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 150	2 PCS			
DN 100	12 PCS			
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)			
Disc	EN JS 1030 (GGG 40)			
Seat	EPDM			
Spring	AISI 302 (STAINLESS STEEL)			
Stem	AISI 420 (STAINLESS STEEL)			
Stop Pin	AISI 420 (STAINLESS STEEL)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,12	0,52	2,08	0,044	0,043
CONTROL FOR DISPATCH				
INSIDE CLEANING	OK	DUYAR		
PAINTING&COLOR	BLUE	DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.		
END COVER	OK	Uğur Mumcu Mh. 2347 Sk. No:7/A Sultangazi/İST.		
MARKING	OK	Tel: 0212 668 18 08 (Pbx) Fax: 0212 594 23 65		
		Halic Kurumlar V.D.: 320 003 9012		
		Mersis No: 0320003901200011		
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN		

DVF 20-047