



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

23.11.2017

CLIENT

P.V.F. TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE

BALL VALVE

NOMINAL DIAMETER (DN) mm

DN 050 DN 065 DN 080 DN 100

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS 3148, EN ISO 17292

END CONNECTION

BS EN 1092-2

QUANTITY

120

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 050

50 PCS

DN 065

10 PCS

DN 080

40 PCS

DN 100

20 PCS

SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

O-Ring

EPDM

Flange

EN JL 1040 (GG 25)

Lever

St 37 (ÇELİK)

Stem

AISI 420 (STAINLESS
STEEL)

Ball

STAINLESS STEEL

Seals

PTFE

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,12

0,49

2,07

0,045

0,042

INSIDE CLEANING

PAINTING&COLOR

END COVER

MARKING

OK

BLUE

OK

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.
Osmangazi Mh. 2653 Sk. No:7/1 Kırac-Esenyurt / İSİT
Tel: 0212 444 82 62 Fax: 0212 355 07 47
Marmara Kurumlar V.D.: 320 003 9012
Mersis No: 0320003991200011

INSPECTOR /

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

DVF 20-047

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAC / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve