



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	1024/2017				
	DATE	20.10.2017				
	CLIENT	P.V.F.TRADERS D.O.O.				
NAME OF PRODUCT						
TYPE OF VALVE	GLOBE VALVE					
NOMINAL DIAMETER (DN) mm	DN 032 DN 150 DN 080 DN 100 DN 080 DN 050					
NOMINAL PRESSURE (PN) bar	PN 16					
STANDARD / DESIGN	TS EN 13789					
END CONNECTION	TS EN 1092-2					
QUANTITY	93					
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY			
DN 032	18 PCS					
DN 150	5 PCS					
DN 080	10 PCS					
DN 100	10 PCS					
DN 080	20 PCS					
DN 050	30 PCS					
SPECIFICATION OF MATERIALS						
Body	EN JL 1040 (GG 25)	Packing	GRAFİT (GRAPHITE)			
Flange	EN JL 1040 (GG 25)	Packing Gland	CuZn40Pb2 (BRASS)			
Handwheel	EN JL 1040 (GG 25)	Gasket	KLINGERIT			
Stem	AISI 420 (STAINLESS STEEL)					
Disc	AISI 420 (STAINLESS STEEL)					
Seat	AISI 304 (STAINLESS STEEL)					
TEST CONDITIONS						
TEST LIQUID	WATER					
BODY TEST	24 BAR					
LEAKAGE TEST	18 BAR					
TEST STANDART NO	TS EN 12266-1					
TYPICAL CHEMICAL ANALYSIS						
C	Mn	Si	P	S	Zn	
3,12	0,56	2,1	0,041	0,043		39,41
CONTROL FOR DISPATCH						
INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar Y.D.: 320 003 9012 Mersis No: 0320003901200011				
PAINTING&COLOR	BLUE					
END COVER	OK					
MARKING	OK					
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN				

DVF 20-047