



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

22.12.2017

CLIENT

P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE

METAL SEATED GATE VALVE

NOMINAL DIAMETER (DN) mm

DN 050 DN 080 DN 100 DN 150 DN 080

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS EN 1171

END CONNECTION

BS EN 1092-2

QUANTITY

68

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 050

20 PCS

DN 080

20 PCS

DN 100

17 PCS

DN 150

1 PCS

DN 080

10 PCS

SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

Gasket

EPDM

Bonnet

EN JL 1040 (GG 25)

Handwheel

EN JL 1040 (GG 25)

Wedge

EN JL 1040 (GG 25)

Stem

AISI 420 (STAINLESS STEEL)

Seats

CuZn40Pb2 (BRASS)

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,12

0,48

2,08

0,05

0,042

INSIDE CLEANING

OK

PAINTING&COLOR

BLUE

END COVER

OK

MARKING

INSPECTOR /

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.
OSMANGAZI Mh. 2653 Sk. No:7/1 KIRAC / ESENYURT / İSTANBUL
Tel: 0212 444 82 62 Fax: 0212 355 07 47
Marmara Kurumlar Y.D.: 320 003 9012
Mersis No: 0320003901200011

DVF 20-047

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.
OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAC / ESENYURT / İSTANBUL - TÜRKİYE
TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47
website: www.duyarvalve.com e-mail: info@duyarvalve