



QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO		
		DATE	23.11.2017	
		CLIENT	P.V.F.TRADERS D.O.O.	
NAME OF PRODUCT				
TYPE OF VALVE		RESILIENT SEATED GATE VALVE		
NOMINAL DIAMETER ( DN ) mm		DN 080		
NOMINAL PRESSURE (PN) bar		PN 16		
STANDARD / DESIGN		TS EN 1171		
END CONNECTION		BS EN 1092-2		
QUANTITY		5		
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 080	5 PCS			
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)			
Bonnet	EN JL 1040 (GG 25)			
Handwheel	EN JL 1040 (GG 25)			
Wedge	GGG 40 / RUBBER PLATED			
Stem	AISI 420 (STAINLESS STEEL)			
Gasket	EPDM			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,1	0,48	2,07	0,041	0,037
INSIDE CLEANING	OK			 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmanlı Mah. 2653 Sok. No: 7/1 KIRIÇ / ESEN YURT / İSTANBUL - TÜRKİYE Tel: 0212 444 82 62 - Fax: +212 355 07 47 Marmara Kurumları Y.D. 320 007 01 Mersis No: 320903971200011
PAINTING&COLOR	BLUE			
END COVER	OK			
MARKING	OK			
INSPECTOR /		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN		