



# QUALITY CERTIFICATE

## EN 10204 / 3.1

REPORT NO

DATE

22.12.2017

CLIENT

P.V.F. TRADERS D.O.O.

### NAME OF PRODUCT

TYPE OF VALVE

RESILIENT SEATED GATE VALVE

NOMINAL DIAMETER (DN) mm

DN 150

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS EN 1171

END CONNECTION

BS EN 1092-2

QUANTITY

5

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 150

5 PCS

### SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

Bonnet

EN JL 1040 (GG 25)

Handwheel

EN JL 1040 (GG 25)

Wedge

GGG 40 / RUBBER PLATED

Stem

AISI 420 (STAINLESS STEEL)

Gasket

EPDM

### TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

### TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,1

0,48

2,07

0,041

0,037

INSIDE CLEANING

OK

PAINTING&amp;COLOR

BLUE

END COVER

OK

MARKING

INSPECTOR /

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.  
Osmancazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST  
Tel: 0212 444 82 62 Fax: 0212 355 07 47  
Marmara Kurumlar V.D.: 320 003 9012  
Mersis No: 0320003901200011

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

DVF 20-047

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve