



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	814/2018		
	DATE	12.01.2018		
	CLIENT	P.V.F.TRADERS D.O.O.		
NAME OF PRODUCT				
TYPE OF VALVE		CHECK VALVE WITH SPRING		
NOMINAL DIAMETER (DN) mm		DN 080 DN 040		
NOMINAL PRESSURE (PN) bar		PN 16		
STANDARD / DESIGN		TS EN 12334		
END CONNECTION		TS EN 1092-2		
QUANTITY		16		
Nominal Diameter		QUANTITY	QUANTITY	
DN 080		6 PCS		
DN 040		10 PCS		
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)	Seat	AISI 304 (Stainless Steel)	
Bonnet	EN JL 1040 (GG 25)	Gasket	Klingeit	
Spring	AISI 302 (Stainless Steel)			
Stem DN125..300	AISI 302 (Stainless Steel)			
Stem DN15..100	EN JL 1040 (GG 25)			
Disc	AISI 420 (Stainless Steel)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,1	0,53	2,07	0,04	0,043
INSIDE CLEANING	OK			
PAINTING&COLOR	BLUE			
END COVER	OK			
MARKING	OK			
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN		
 DUYAR VANA MAKİNA SAN. ve TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kırac-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar V.D.: 320 003 9012 Maks. St. 2320002001200011				

DVF 20-047