



# QUALITY CERTIFICATE

## EN 10204 / 3.1

REPORT NO

DATE

23.11.2017

CLIENT

P.V.F.TRADERS D.O.O.

### NAME OF PRODUCT

TYPE OF VALVE

CHECK VALVE WITH SPRING

NOMINAL DIAMETER ( DN ) mm

DN 080 DN 150

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS EN 12334

END CONNECTION

TS EN 1092-2

QUANTITY

6

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 080

1 PCS

DN 150

5 PCS

### SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

Seat

AISI 304 (Stainless Steel)

Bonnet

EN JL 1040 (GG 25)

Gasket

Klingeit

Spring

AISI 302 (Stainless Steel)

Stem DN125..300

AISI 302 (Stainless Steel)

Stem DN15..100

EN JL 1040 (GG 25)

Disc

AISI 420 (Stainless Steel)

### TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

### TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,1

0,53

2,07

0,04

0,043

INSIDE CLEANING

PAINTING&amp;COLOR

OK

END COVER

BLUE

MARKING

OK



DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.  
Osmangazi Mh. 2653 Sk. No:7/1 KIRIÇ-ESENYURT / İSİ  
Tel: 0212 444 82 62 Fax: 0212 355 07 47  
Marmara Kurumlar V.D: 320 003 9011  
Mersis No: 0320003901200011

INSPECTOR /

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

DVF 20-047

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRIÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve