



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO	848/2017
DATE	17.03.2017
CLIENT	P.V.F.TRADERS D.O.O.

NAME OF PRODUCT

TYPE OF VALVE	RESILIENT SEATED GATE VALVE
NOMINAL DIAMETER (DN) mm	DN 080 DN 125 DN 150 DN 050
NOMINAL PRESSURE (PN) bar	PN 16
STANDARD / DESIGN	TS EN 1171
END CONNECTION	BS EN 1092-2
QUANTITY	40

Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY
DN 080	10 PCS		
DN 125	15 PCS		
DN 150	5 PCS		
DN 050	10 PCS		

SPECIFICATION OF MATERIALS

Body	EN JL 1040 (GG 25)	Packing	PTFE
Bonnet	EN JL 1040 (GG 25)	O-Ring	EPDM
Handwheel	EN JL 1040 (GG 25)	Bonnet Extension	CuZn40Pb2 (BRASS)
Wedge	GGG 40 / RUBBER PLATED	Sight Glass	ACRYLIC
Stem	AISI 420 (STAINLESS STEEL)	Sight Glass Gasket	EPDM
Gasket	EPDM	Label Plate	AISI 304 (STAINLESS STEEL)

TEST CONDITIONS

TEST LIQUID	WATER
BODY TEST	24 BAR
LEAKAGE TEST	18 BAR
TEST STANDART NO	TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C	Mn	Si	P	S	Rm	Rp	A
3,1	0,48	2,07	0,041	0,037	285	211	0,62

CONTROL FOR DISPATCH

INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. ve TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar V.D.: 320 003 9012 Mersis No: 0320003901200011
PAINTING&COLOR	BLUE	
END COVER	OK	
MARKING	OK	

INSPECTOR / Tamer SOYDAN

QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN

DVF 20-047