



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO	1024/2017			
	DATE	10.11.2017			
	CLIENT	P.V.F.TRADERS D.O.O.			
NAME OF PRODUCT					
TYPE OF VALVE		WAFER TYPE BUTTERFLY VALVE STAINLESS STEEL CL			
NOMINAL DIAMETER (DN) mm		DN 150 DN 050			
NOMINAL PRESSURE (PN) bar		PN 16			
STANDARD / DESIGN		BS EN 593 -TS EN 593			
END CONNECTION		BS EN 1092-2			
QUANTITY		8			
Nominal Diameter		QUANTITY			
DN 150		3 PCS			
DN 050		5 PCS			
SPECIFICATION OF MATERIALS					
Body	EN JL 1040 (GG 25)	Seat	EPDM-NBR		
Disc	CF 8 (STAINLESS STEEL)	Stem Bearing	LUBRICATED BRONZE		
Lever	EN JS 1030 (GGG 40)				
Top Stem	AISI 420 (STAINLESS STEEL)				
Bottom Stem	AISI 420 (STAINLESS STEEL)				
O-Ring	EPDM				
TEST CONDITIONS					
TEST LIQUID	WATER				
BODY TEST	24 BAR				
LEAKAGE TEST	18 BAR				
TEST STANDART NO	TS EN 12266-1				
TYPICAL CHEMICAL ANALYSIS					
C	Mn	Si	P	S	Zn
3,1	0,47	2,09	0,051	0,042	39,41
CONTROL FOR DISPATCH					
INSIDE CLEANING	OK	 DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. Osmangazi Mh. 2653 Sk. No:7/1 KIRIÇ-ESENYURT / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar Y.D.: 320 000 9012 Mersis No: 0320003901200011			
PAINTING&COLOR	RED				
END COVER	OK				
MARKING	OK				
INSPECTOR / Tamer SÖYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN			