



<b>QUALITY CERTIFICATE</b> <b>EN 10204 / 3.1</b>	REPORT NO	1024/2017				
	DATE	10.11.2017				
	CLIENT	P.V.F.TRADERS D.O.O.				
<b>NAME OF PRODUCT</b>						
TYPE OF VALVE		Y TYPE STRAINER				
NOMINAL DIAMETER ( DN ) mm		DN 050 DN 065 DN 080 DN 100 DN 125 DN 032 DN 150 DN				
NOMINAL PRESSURE (PN) bar		PN 16				
STANDARD / DESIGN		TS 11494				
END CONNECTION		TS EN 1092-2				
QUANTITY		195				
Nominal Diameter		QUANTITY	Nominal Diameter	QUANTITY		
DN 050		30 PCS	DN 150	10 PCS		
DN 065		10 PCS	DN 200	5 PCS		
DN 080		50 PCS	DN 025	20 PCS		
DN 100		50 PCS				
DN 125		10 PCS				
DN 032		10 PCS				
<b>SPECIFICATION OF MATERIALS</b>						
Body	EN JL 1040 (GG 25)					
Bonnet	EN JL 1040 (GG 25)					
Filter	AISI 304 (STAINLESS)					
Gasket	KLINGERIT					
Plug Gasket	COPPER					
Plug	St 37 (STEEL)					
<b>TEST CONDITIONS</b>						
TEST LIQUID	WATER					
BODY TEST	24 BAR					
LEAKAGE TEST	18 BAR					
TEST STANDART NO	TS EN 12266-1					
<b>TYPICAL CHEMICAL ANALYSIS</b>						
C	Mn	Si	P	S	Zn	
3,12	0,51	2,09	0,032	0,038		39,41
<b>CONTROL FOR DISPATCH</b>						
INSIDE CLEANING	OK		 <b>DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.</b> Osmangazi Mh. 2653 Sk. No:7/1 Kırac-Esenyurt / İST. Tel: 0212 444 82 62 Fax: 0212 355 07 47 Marmara Kurumlar Y.D.: 320 003 9012 Mersis No: 0320009901200011			
PAINTING&COLOR	BLUE					
END COVER	OK					
MARKING	OK					
INSPECTOR / Tamer SOYDAN		QUALITY ASSURANCE MANAGER / Gökhan BAŞMAN				