

Inspection certificate

Sertifikat o kontrolisanju

SERTIFIKAT O KONTROLISANJU INSPECTION CERTIFICATE

Broj / Number: T 1707

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser: **IMMERGAS, S.p.A., Via Cisa Ligure 95 42041 Brescello (RE) ITALIJA /Italy**

preduzeto je/
has been undertaken: kontrolisanje postojećeg proizvoda
the existing product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report: Broj / Number: T 1707

sa dokumentima u prilogu/
with attached documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1707 /
Test report by IMP-CGT-LAB No. T 1707.

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
subject of the inspection: **GASNI KOTAO
GAS BOILER**

proizveden od /
manufactured by : **Immergas S.p.A.
Via Cisa Ligure 95 42041 Brescello (RE), Italija /Italy**

oznaka - tip - serija /
mark - type - series : **MAIOR EOLO...**

vrsta/type: **B₂₂, C_{12(x)}, C_{32(x)}**
kategorija/category: **II_{2H3+}**

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document : **SRPS EN 15502-2-1: 2013**

Sertifikat o kontrolisanju se izdaje na osnovu standarda **SRPS ISO/IEC 17020:2012** .
The inspection certificate is issued on the basis of standard **SRPS ISO/IEC 17020:2012** .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical inspection until the date :

12.04.2022.


izdat od / issued by :

mesto, datum / place, date

Beograd, 12.04.2017.



**RUKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER**
Kristina Petković, M.Sc.M.E.



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1707

Strana / Page: 2 / 2

Prilog A /
Annex A

oznaka - tip - serija /
mark - type - series :

MAIOR EOLO ...

vrsta/type: B₂₂, C_{12(x)}, C_{32(x)}
kategorija/category: II_{2H3+}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
MAIOR EOLO ...		
...24 4E	Q _n =10,6 ÷ 25,8 kW P _n =9,3 ÷ 24 kW P _n =7,0 ÷ 24 kW*)	2H: p= 20 mbar 3B/P:p = 37mbar PMS=3 bar, Ts=90° C, PMW= 10 bar IPX5D, 230V, 50 Hz - za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
...28 4E	Q _n =12,7 ÷ 29,7 kW P _n =11,2 ÷ 28 kW P _n =8,5 ÷ 28 kW*)	
...32 4E	Q _n =14,8 ÷ 34,2 kW P _n =12,9 ÷ 32 kW P _n =10,5 ÷ 32 kW*)	
...X 28	Q _n =12,7 ÷ 29,7 kW P _n =11,2 ÷ 28 kW P _n =8,5 ÷ 28 kW*)	
Napomene / notes: *) za / for: TSV/DHW		

Sertifikat o kontrolisanju
Inspection certificate