



SERTIFIKAT

O PREGLEDU TIPÄ/ Type examination

Broj / Number : T 1952

POJEDINAČNI PREGLED/Single examination

Strana / Page : 1/2

Na zahtev naručioca / **IMMERGAS, Europe s.r.o. Slovačka / IMMERGAS,**
By the request of purchaser: *Europe s.r.o. Slovakia*

preduzeto je/ **Kontrolisanje novog proizvoda /**
has been undertaken: *Inspection of the new product*

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number: T 1952

sa dokumentima u prilogu/ **- Prospekt proizvoda / Catalogue pages of product;**
with attached documents: **- Uputstvo za instaliranje i korišćenje /**
Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju T1952 IMP CGT/ Test reports
T1952 IMP CGT

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja / **GASNI KONVENCIONALNI KOTAO /**
subject of the inspection: *GAS TRADITIONAL BOILER*

proizveden od / **IMMERGAS, Europe s.r.o. Priemyselna ul. 4789,**
manufactured by : *Poprad-Matejovce 05951 Slovačka / Slovakia*

oznaka - tip - serija / **EOLO MYTHOS DOM ... 1E /**
mark - type - series : *EOLO MYTHOS DOM ... 1E*

vrsta/type: **B₂₂, C₁₂, C₃₂**
kategorija/category: **II_{2H3+}**

kako je specificirano u Prilogu **- Pravilnik o zahtevima za projektovanje, izradu i**
A, zadovoljava zahteve **ocenjivanje usaglašenosti gasnih aparata ("Sl.**
navedene u / **gl. RS", br. 41/2015)**
as specified in the Annex A, **- SRPS EN 15502-2-1:2013**
meets the requirements listed in:

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012
i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.
Ocenjivanje sprovedeno / Evaluation performed from 01.11.2019. ÷ 27.12.2019.

izdat od / issued by :
UKOVODIOCA CENTRA ZA GASNU
TEHNIKU
GAS TECHNIQUE CENTRE MANAGER
Kristina Petković dipl.maš.inž.

mesto, datum / place, date : **M.P. /**
S.P.

Beograd, 27.12.2019.

Sertifikat
Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impqt@pupin.rs



Prilog A /
Annex A

Broj /
Number: T 1952
Strana /
Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

EOLO MYTHOS DOM ... 1E /
EOLO MYTHOS DOM ... 1E

vrsta/type: B₂₂, C₁₂, C₃₂
kategorija/category: II_{2H3+}

Sertifikat Certificate

oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description
EOLO MYTHOS DOM ...		
... 10 1E	Q _n = 10,6 (8,7*) ÷ 11,7 kW P _n = 9,0 (7,2*) ÷ 10,0 kW	- 2H: p = 20 mbar - 3P: p = 30 mbar
... 18 1E	Q _n = 10,6 (8,7*) ÷ 20,2 kW P _n = 9,0 (7,2*) ÷ 18,0 kW	- PMS 3 bar - PMW 10 bar - IPX5D,
... 24 1E	Q _n = 10,6 (8,7*) ÷ 25,3 kW P _n = 9,0 (7,2*) ÷ 23,0 kW	- 230V, 50 Hz, 130W

Napomena / note: *) za / for: TSV - toplu sanitarnu vodu / DHW - domestic hot water

Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year
within the assessment of the Declaration of Conformity with the type!



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
mpcgt@pupin.rs