



Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPA/ Type examination

Broj / Number: T 2223

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: **IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)
Italija / Italy**

preduzeto je/
has been undertaken: **Kontrolisanje novog proizvoda / inspection of the new
product**

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number: T 2223

sa dokumentima u prilogu/
with attached documents:

- Prospekt proizvoda / Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje / Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaj o ispitivanju KIWA broj 2011527 / Test report KIWA No 2011527

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI KOTAO / GAS BOILER**

proizveden od /
manufactured by: **IMMERGAS Europe s.r.o., Priemyselna Ulica 4789 SK-
05951 Poprad Matejovce Slovačka / Slovakia**

oznaka - tip - serija /
mark - type - series: **EOLO STAR 24 4E**
vrsta/type: C₁₂, C₃₂, C₄₂, C₅₂, C₆₂, C₈₂, B₂₂, B₃₂
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in: **Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2013**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /

The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 19.10.2022. ÷ 17.11.2022.



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE

mesto, datum / place, date:

Beograd, 17.11.2022.



Kristina Petković dipl.maš.inž.

Ime, Prezime / Name, Surname



Sertifikat Certificate

Prilog A /
Annex A

Broj / Number: T 2223
Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

EOLO STAR 24 4E

vrsta/type: C₁₂, C₃₂, C₄₂, C₅₂, C₆₂, C₈₂, B₂₂, B₃₂
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
EOLO STAR 24 4E			
EOLO STAR 24 4E	Q _n =12,8(7,6*)÷25,5 kW P _n =11,5 (6,8*)÷23,8 kW	2H: p=20 mbar 3P: p=37 mbar PMS=3 bar. PWM=10 bar T=90°C 230 V, 50 Hz, 130W IP X5D, NO _x =3	zidni gasni kotao- za grejanje i toplu sanitarnu vodu/ wall hung gas condensing boiler for heating and domestic hot water
Napomena / note: * za TSV / for DHW			

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year
within the assessment of the Declaration of Conformity with the type!



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impopt@pupin.rs