



Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPa/ Type examination **Broj / Number:** T 1914
 POJEDINAČNI PREGLED/Single examination **Strana / Page:** 1 / 2

Na zahtev naručioca / **IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)**
By the request of purchaser: **Italija / Italy**

preduzeto je/ **Kontrolisanje novog proizvoda / inspection of the new**
has been undertaken: **product**

u vezi sa Izveštajem o usaglašenosti/ **Broj / Number:** T 1914
in relation to Inspection report:

sa dokumentima u - Prospekt proizvoda / *Catalogue pages of product;*
prilogu/ - Uputstvo za instaliranje i korišćenje /
with attached documents: *Installation and user's manual;*
- Dokumentacija o proizvodu / *Product documentation;*
- Izveštaj o ispitivanju IMP-CGT T 1409/
Test report IMP- CGT T 1409

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja / **GASNI KONDENZACIONI KOTAO /**
subject of the inspection: **GAS CONDENSING BOILER**

proizveden od / **IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)**
manufactured by : **Italija / Italy**

oznaka - tip - serija / **VICTRIX PRO ... 1I**
mark - type - series :

vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata ("Sl.
gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /

The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 19.06.2019. ÷ 28.06.2019.

izdat od / issued by :

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum / place, date

Beograd, 28.06.2019



Ime , Prezime / Name , Sumame

A
048 19
INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impct@pupin.rs



Prilog A /
Annex A

Broj / Number: T 1914

Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series : VICTRIX PRO ... II

vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: II_{2H3P}

Sertifikat Certificate

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
VICTRIH PRO ...		
... 35 I I	Q _n =3,9 ÷ 34,9 kW (Hi) P _n =3,4 ÷ 34,0 kW ^{1.)}	zidni gasni kondenzacioni kotao- samo za grejanje / wall hung gas condensing boiler only for heating
... 55 I I	Q _n =5,5 ÷ 51,4 kW (Hi) P _n =5,0 ÷ 50,0 kW ^{1.)}	
... 80 I I	Q _n =7,6 ÷ 75,3 kW (Hi) P _n =7,2 ÷ 73,0 kW ^{1.)}	
... 100 I I	Q _n =9,4 ÷ 92,3 kW (Hi) P _n =9,0 ÷ 90,0 kW ^{1.)}	
... 120 I I	Q _n =11,4 ÷ 114,1 kW (Hi) P _n =11,0 ÷ 111,0 kW ^{1.)}	
Napomena / note: 1.) pri / at: t ₂ /t ₁ =80/60°C		

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year
within the assessment of the Declaration of Conformity with the type!

Poslednja nadzorna poseta obavljena 12.06.2021.
The last audit was done 12.06.2021.



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impctg@pupin.rs