



Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPA/ Type examination

Broj / Number: T 22-2126-1

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

I Aneks sertifikata broj T 2126

Na zahtev naručioca /

IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)

By the request of purchaser:

Italija / Italy

preduzeto je/

has been undertaken:

Kontrolisanje novog proizvoda / inspection of the new

product

u vezi sa Izveštajem o usaglašenosti/

in relation to Inspection report:

Broj / Number:

T 22-2126-1

sa dokumentima u

prilogu/

with attached documents:

- Prospekt proizvoda / Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje / Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju TUV Rheinland broj 28118398 201 - 204 i IMQ broj AG16-0002377-01 M01 RPG02 / Test report TUV Rheinland N° 28118398 201 - 204 and IMQ N° AG16-0002377-01 M01 RPG02

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:

INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /

subject of the inspection:

GASNI KONDENZACIONI KOTAO /

GAS CONDENSING BOILER

proizveden od /

manufactured by :

IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)

Italija / Italy

oznaka - tip - serija /

mark - type - series :

VICTRIX TERA...

vrsta/type: C13, C33, C53, C63, C83, C93, B23P, B53, B33

kategorija/category: II2H3P

kako je specificirano u Prilogu

A, zadovoljava zahteve

navedene u /

as specified in the Annex A, meets

the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu i

ocenjivanje usaglašenosti gasnih aparata ("Sl. gl.

RS", br. 41/2015)

SRPS EN 15502-2-1:2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i

Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /

The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012

and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 20.10.2022. ÷ 17.11.2022.

izdat od / issued by :

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/

INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE

Kristina Petković dipl.maš.inž.

mesto, datum / place, date :

Beograd, 17.11.2022.



Ime, Prezime / Name, Surname



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impqgt@pupin.rs



Prilog A /
Annex A

Broj / Number: T 22-2126-1
Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

VICTRIX TERA...

vrsta/type: C₁₃, C₃₃, C₅₃, C₆₃, C₈₃, C₉₃, B_{23P}, B₅₃, B₃₃
kategorija/category: II_{2H3P}

Sertifikat Certificate

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
VICTRIX TERA ...		
... 28 I	Q _n = 4,5 ÷ 24,6 (28,6*) kW P _n = 4,3 ÷ 24,0 (28,0*) kW	zidni gasni kondenzacioni kotao / wall hung gas condensing boiler
... 32 I	Q _n = 5,1 ÷ 28,6 (32,6*) kW P _n = 4,9 ÷ 28,0 (28,0*) kW	
... 38 I	Q _n = 6,3 ÷ 32,7 (39,0*) kW P _n = 6,1 ÷ 32,0 (37,9*) kW	
... 24 PLUS	Q _n = 4,5 ÷ 24,6 (28,8*) kW P _n = 4,3 ÷ 24,0 (28,3*) kW	
... 35 PLUS I	Q _n = 6,3 ÷ 32,7 (39,0*) kW P _n = 6,1 ÷ 32,0 (37,9*) kW	

*Napomena / note: za TSV / for DHW

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year
within the assessment of the Declaration of Conformity with the type!



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impegt@pupin.rs