

Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPa/ Type examination

Broj / Number: T 23-2113-1

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: **IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)
Italija / Italy**

preduzeto je/
has been undertaken: **Kontrolisanje novog proizvoda / inspection of the new
product**

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number: T 23-2113-1

sa dokumentima u
prilogu/
with attached documents:

- Prospekt proizvoda / Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje / Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaj o ispitivanju TUV Rheinland broj 28111740 / Test report TUV Rheinland No 28111740

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI KONDENZACIONI KOTAO /
GAS CONDENSING BOILER**

proizveden od /
manufactured by: **IMMERGAS, Via Cisa Ligure 95, 42041 Brescello (RE)
Italija / Italy**

oznaka - tip - serija /
mark - type - series: **VICTRIX PRO ... 2ErP**
vrsta/type: **B₂₃, C₁₃, C₃₃, C₆₃, B₃₃, B_{53p}**
kategorija/category: **II_{2H3P}**

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in: **Pravilnik o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata ("Sl.
gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2017**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from **11.05.2023. ÷ 31.10.2023..**

izdat od / issued by :

**INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE**

mesto, datum / place, date :

Beograd, 31.10.2023.

M.P.
S.P.

Kristina Petković dipl.maš.inž.


Ime, Prezime / Name, Surname

CGTit 4.001 V.2



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs





Sertifikat Certificate

Prilog A / Annex A

Broj / Number: T 23-2113-1

Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series : VICTRIX PRO ... 2ErP

vrsta/type: B₂₃, C₁₃, C₃₃, C₆₃, B₃₃, B_{53p}
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
VICTRIX PRO ...			
... 35 2ErP	Q _n =3,9 ÷ 34,9 kW (Hi) P _n =3,4 ÷ 34,0 kW ^{1.)}	zidni gasni kondenzacioni kotao- samo za grejanje / wall hung gas condensing boiler only for heating	
... 55 2ErP	Q _n =5,5 ÷ 51,3 kW (Hi) P _n =5,0 ÷ 49,9 kW ^{1.)}		
... 68 2 ErP	Q _n = 8,6 ÷ 65,3 kW (Hi) P _n = 8,2 ÷ 63,5 kW ^{1.)}		2H: p=20 mbar 3P: p=37 mbar PMS=4,4 bar, T=90°C
... 80 2ErP	Q _n =8,6 ÷ 75,3 kW (Hi) P _n =8,2 ÷ 73,0 kW ^{1.)}		230 V, 50 Hz, IP X5D
... 100 2ErP	Q _n =9,8 ÷ 92,3 kW (Hi) P _n =9,4 ÷ 90,0 kW ^{1.)}		
... 120 2ErP	Q _n =11,4 ÷ 114,1 kW (Hi) P _n =11,0 ÷ 111,0 kW ^{1.)}		
Napomena / note: 1.) pri / at: t ₂ /t ₁ =80/60°C			

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year
within the assessment of the Declaration of Conformity with the type!



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Vulgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impegt@pupin.rs