

**SERTIFIKAT O KONTROLISANJU**  
**INSPECTION CERTIFICATE**

Broj / Number: T 1220

Strana / Page: 1/2

**Na zahtev naručioca /**  
*By the request of purchaser:* **Vaillant GmbH- Predstavništvo u Srbiji ,**  
**Radnička 59, Beograd, Srbija/Serbia**

**preduzeto je/**  
*set to:* kontrolisanje novog proizvoda  
*the new product inspection*

**u vezi sa Izveštajem o kontrolisanju /**  
*in relation to Inspection report:*

Broj / Number: T 1220

**sa dokumentima u prilogu/**  
*with enclosed documents:*

- Prospekt proizvoda /  
*Catalogue pages of product;*
- Uputstvo za instaliranje i korišćenje /  
*Installation and user's manual;*
- Dokumentacija o proizvodu /  
*Product documentation;*
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1220 /  
*Test report by IMP-CGT-LAB No. T 1220.*

**INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:**  
*INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:*

**predmet kontrolisanja /**  
*the inspection object :*

**GASNI KONDENZACIONI KOTAO**  
**GAS CONDENSING BOILER**

**proizveden od /**  
*manufactured by :*

**Vaillant GmbH, Berghauser Strasse 40**  
**42859 Remscheid, Nemačka/Germany**

**oznaka - tip - serija /**  
*mark - type - series :*

**VAILLANT eco TEC plus VU INT ...**

*vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>*  
*kategorija/category: II<sub>2H3B/P</sub>*

**kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /**  
*as specified in the Annex A, meets the requirements sa decribed in :*

**referentnom dokumentu /**  
*reference document :*

**SRPS EN 483:2010; SRPS EN 625:2011;**  
**SRPS EN 677:2011.**

**Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002 .**  
*The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002 .*

**Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa periodičnim kontrolisanjem do dana /**

*Surveillance of the inspection object compliance is assured by periodical inspection until the date :*

11.07.2017.

mesto, datum / place, date :

Beograd, 12.07.2012.



izdat od / issued by :

**RUKOVODILAC CENTRA ZA GASNU TEHNIKU**  
**GAS TECHNIQUE CENTRE MANAGER**

mr. Vladeta Buljak, dipl. ing.

Ime, Prezime / Name, Surname



**SERTIFIKAT O KONTROLISANJU**  
**INSPECTION CERTIFICATE**

Broj / Number: T 1220

Strana / Page: 2/2

**Prilog A /**

**Annex A**

oznaka - tip - serija /  
 mark - type - series :

**VAILLANT eco TEC plus VU INT...**

vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>

kategorija/category: II<sub>2H3B/P</sub>

detaljno oznaka - tip - serija / mark - type - series specification :			tehničke karakteristike / technical characteristics :		kratak opis / short description :
<b>VAILLANT eco TEC plus VU INT...</b>					zidni gasni kotao- / wall hung gas boiler
... eco TEC plus VU INT	466	/4-5	$Q_n = 12,5 \div 45,0 \text{ kW}$ $P_n = 12,3 \div 44,1 \text{ kW}$	2H: p=20 mbar 3B/P: p=30mbar PMS=3 bar, $T_s = 90^\circ \text{ C}$	- samo za grejanje / - heating only
	656	/4-5	$Q_n = 14,0 \div 65,0 \text{ kW}$ $P_n = 13,8 \div 63,7 \text{ kW}$	230V, 50 Hz, IP X4D NO <sub>x</sub> : 5	

Inspection certificate

Sertifikat o kontrolisanju