



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

18.03.2022

CLIENT

P.V.F. TRADERS D.O.O.-
DYV2022000000107

NAME OF PRODUCT

TYPE OF VALVE

SPRINKLER UPRIGHT

NOMINAL DIAMETER (DN) mm

DN

NOMINAL PRESSURE (PN) bar

PN 12

STANDARD / DESIGN

TS EN 12259-1

END CONNECTION

ISO 7/1

QUANTITY

500

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN

500 PCS

SPECIFICATION OF MATERIALS

Body

CuZn40Pb2 (Ms 58)

Bulb slot

CuZn40Pb2 (Ms 58)

Bulb

Glass+ Liquid

Packing

Be - Ni Alloy + Teflon Coated

Deflector

Stainless Steel (CF 8)

Grub

Stainless Steel (CF 8)

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

34,5 BAR

LEAKAGE TEST

34,5 BAR

TEST STANDART NO

TS EN 12845 + A2

TYPICAL CHEMICAL ANALYSIS

Mn

P

Cu

Pb

Sn

Zn

0.04

0,01

57,42

2.71

0,038

39,41

INSIDE CLEANING

PAINTING&COLOR

OK

END COVER

MARKING

OK

INSPECTOR / Zafer KUVVET

QUALITY ASSURANCE DIRECTOR / Vayxel AILGAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.
OSMANGAZI MAH.2653 SOK. NO : 7 / 1 KIRAÇ / ESENYURT / İSTANBUL -

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.
Osmancazi Mah. 2653 Sok. No:7/1 Kiraç / Eseyurt / İstanbul