



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

18.03.2022

CLIENT

P.V.F. TRADERS D.O.O.-
DYV2022000000107

NAME OF PRODUCT

TYPE OF VALVE

TWO WAY INLET

NOMINAL DIAMETER (DN) mm

DN 100 DN 100

NOMINAL PRESSURE (PN) bar

PN 21

STANDARD / DESIGN

END CONNECTION

QUANTITY

8

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 100

4 PCS

DN 100

4 PCS

SPECIFICATION OF MATERIALS

Body

Brass

Disc

Brass

O-Ring

Vulcanized Rubber

Bonnet

Brass

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

42 BAR

LEAKAGE TEST

21 BAR

TEST STANDART NO

TYPICAL CHEMICAL ANALYSIS

Mn

P

Cu

Pb

Sn

Zn

0,04

0.01

57,42

2.71

0,038

39,42

INSIDE CLEANING

PAINTING&COLOR

OK

END COVER

MARKING

OK

INSPECTOR / Zafer KIVVET

QUALITY ASSURANCE DIRECTOR / Veynel ATILGAN

DUYAR

DVE-20-047

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAC / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

Osmancazi Mah. 2653 Sok. No:7 Esenyurt/İSTANBUL

Pbx: 444 82 62 Faks: 0 212 355 07 47

Marmara Kurumlar V.D. : 320 003 9012