



# QUALITY CERTIFICATE EN 10204 / 3.1

REPORT NO

DATE

18.03.2022

CLIENT

P.V.F. TRADERS D.O.O.-  
DYV2022000000107

## NAME OF PRODUCT

TYPE OF VALVE

FLOW SWITCH

NOMINAL DIAMETER ( DN ) mm

DN 080

NOMINAL PRESSURE (PN) bar

450 PSI - PN 31

STANDARD / DESIGN

TSE - FM 1042 - UL 346

END CONNECTION

QUANTITY

7

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 080

7 PCS

## SPECIFICATION OF MATERIALS

Stem

AISI 304

Gasket

NBR

Bonnet

AETIAL 150 ALUMINIUM

Welded Neck

St 37 (steel)

## TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

62 BAR

LEAKAGE TEST

62 BAR

TEST STANDART NO

EN 12259-5

## TYPICAL CHEMICAL ANALYSIS

INSIDE CLEANING

PAINTING&amp;COLOR

END COVER

MARKING

OK

OK

OK

INSPECTOR / Zafar KUVVET

QUALITY ASSURANCE DIRECTOR / Veysel ATILGAN