



QUALITY CERTIFICATE

EN 10204 / 3.1

REPORT NO

DATE

22.03.2019

CLIENT

P.V.F.TRADERS D.O.O.-
DYV2019000000094

NAME OF PRODUCT

TYPE OF VALVE

METAL SEATED GATE VALVE

NOMINAL DIAMETER (DN) mm

DN 065

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS EN 1171

END CONNECTION

BS EN 1092-2

QUANTITY

10

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 065

10 PCS

SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

Gasket

EPDM

Bonnet

EN JL 1040 (GG 25)

Handwheel

EN JL 1040 (GG 25)

Wedge

EN JL 1040 (GG 25)

Stem

AISI 420 (STAINLESS STEEL)

Seats

CuZn40Pb2 (BRASS)

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,12

0,48

2,08

0,05

0,042

INSIDE CLEANING

PAINTING&COLOR

OK

END COVER

BLUE

MARKING

OK

INSPECTOR / Zafer KUVVET

QUALITY ASSURANCE MANAGER / Aykut ÖZMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmancazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST.

Tel: 0212 444 82 62 Fax: 0212 355 07 47

Marmara Kurumlar V.D. : 222 235 07 47

DVF-20-047

