

QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO				
	DATE	16.04.2019			
	CLIENT	P.V.F.TRADERS D.O.O.- DYV2019000000134			
NAME OF PRODUCT					
TYPE OF VALVE	SPRINKLER UPRIGHT				
NOMINAL DIAMETER (DN) mm	DN				
NOMINAL PRESSURE (PN) bar	PN 12				
STANDARD / DESIGN	TS EN 12259-1				
END CONNECTION	ISO 7/1				
QUANTITY	400				
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY		
DN	400 PCS				
SPECIFICATION OF MATERIALS					
Body	CuZn40Pb2 (Ms 58)				
Bulb slot	CuZn40Pb2 (Ms 58)				
Bulb	Glass+ Liquid				
Packing	Be - Ni Alloy + Teflon Coated				
Deflector	Stainless Steel (CF 8)				
Grub	Stainless Steel (CF 8)				
TEST CONDITIONS					
TEST LIQUID	WATER				
BODY TEST	34,5 BAR				
LEAKAGE TEST	34,5 BAR				
TEST STANDART NO	TS EN 12845 + A2				
TYPICAL CHEMICAL ANALYSIS					
Mn	P	Cu	Pb	Sn	Zn
0,04	0,01	57,42	2,71	0,038	39,41
INSIDE CLEANING	OK				
PAINTING&COLOR	OK				
END COVER	OK				
MARKING	OK				
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE MANAGER / Aykut ÖZMAN			