



# QUALITY CERTIFICATE

## EN 10204 / 3.1

REPORT NO

DATE

22.03.2019

CLIENT

P.V.F. TRADERS D.O.O.-  
DYV2019000000093

### NAME OF PRODUCT

TYPE OF VALVE

SPRINKLER PENDENT

NOMINAL DIAMETER ( DN ) mm

DN

NOMINAL PRESSURE (PN) bar

PN 12

STANDARD / DESIGN

TS EN 12259-1

END CONNECTION

ISO 7 / 1

QUANTITY

200

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN

200 PCS

### SPECIFICATION OF MATERIALS

Body

CuZn40Pb2(Ms 58)

Bulb slot

CuZn40Pb2(Ms 58)

Bulb

Glass+Liquid

Packing

Be+Ni Alloy+Teflon Coated

Deflector

Stainless Steel (CF 8)

Grub

Stainless Steel (CF 8)

### TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

34,5 BAR

LEAKAGE TEST

34,5 BAR

TEST STANDART NO

TS EN 12845 + A2

### TYPICAL CHEMICAL ANALYSIS

Mn

P

Cu

Pb

Sn

Zn

0,04

0.01

57,42

2,71

0,038

39,42

INSIDE CLEANING

PAINTING&amp;COLOR

OK

END COVER

MARKING

OK

INSPECTOR / Zafer KUVVET

QUALITY ASSURANCE MANAGER / Aykut ÖZMAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmangazi Mh. 2653 Sk. No:7/1 Kiraç-Esenyurt / İST.

Tel: 0212 444 82 62 Fax: 0212 355 07 47

DVF 20-047

DUYAR