



<b>QUALITY CERTIFICATE</b> <b>EN 10204 / 3.1</b>		REPORT NO			
		DATE	16.04.2019		
		CLIENT	P.V.F.TRADERS D.O.O.- DYV2019000000134		
<b>NAME OF PRODUCT</b>					
TYPE OF VALVE		SPRINKLER PENDENT			
NOMINAL DIAMETER ( DN ) mm		DN			
NOMINAL PRESSURE (PN) bar		PN 12			
STANDARD / DESIGN		TS EN 12259-1			
END CONNECTION		ISO 7 / 1			
QUANTITY		200			
Nominal Diameter		QUANTITY			
DN		200 PCS			
<b>SPECIFICATION OF MATERIALS</b>					
Body	CuZn40Pb2(Ms 58)				
Bulb slot	CuZn40Pb2(Ms 58)				
Bulb	Glass+Liquid				
Packing	Be+Ni Alloy+Teflon Coated				
Deflector	Stainless Steel (CF 8)				
Grub	Stainless Steel (CF 8)				
<b>TEST CONDITIONS</b>					
TEST LIQUID	WATER				
BODY TEST	34,5 BAR				
LEAKAGE TEST	34,5 BAR				
TEST STANDART NO	TS EN 12845 + A2				
<b>TYPICAL CHEMICAL ANALYSIS</b>					
Mn	P	Cu	Pb	Sn	Zn
0,04	0,01	57,42	2,71	0,038	39,42
INSIDE CLEANING	OK				
PAINTING&COLOR	OK				
END COVER	OK				
MARKING	OK				
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE MANAGER / Aykut ÖZMAN			