



<b>QUALITY CERTIFICATE</b> <b>EN 10204 / 3.1</b>	REPORT NO			
	DATE	10.09.2020		
	CLIENT	P.V.F.TRADERS D.O.O.- DYV202000000324		
<b>NAME OF PRODUCT</b>				
TYPE OF VALVE	Y TYPE STRAINER			
NOMINAL DIAMETER ( DN ) mm	DN 150 DN 020 DN 040 DN 050 DN 065			
NOMINAL PRESSURE (PN) bar	PN 16			
STANDARD / DESIGN	TS 11494			
END CONNECTION	TS EN 1092-2			
QUANTITY	23			
<b>Nominal Diameter</b>	<b>QUANTITY</b>	<b>Nominal Diameter</b>	<b>QUANTITY</b>	
DN 150	3 PCS			
DN 020	5 PCS			
DN 040	5 PCS			
DN 050	5 PCS			
DN 065	5 PCS			
<b>SPECIFICATION OF MATERIALS</b>				
Body	EN JL 1040 (GG 25)			
Bonnet	EN JL 1040 (GG 25)			
Filter	AISI 304 (STAINLESS STEEL)			
Gasket	KLINGERIT			
Plug Gasket	COPPER			
Plug	St 37 (STEEL)			
<b>TEST CONDITIONS</b>				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
<b>TYPICAL CHEMICAL ANALYSIS</b>				
C	Mn	Si	P	S
3,12	0,51	2,09	0,032	0,038
INSIDE CLEANING				
PAINTING&COLOR	OK			
END COVER	BLUE			
MARKING	OK			
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE MANAGER / Levent GÜNAYDIN		