



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO			
	DATE	10.09.2020		
	CLIENT	P.V.F.TRADERS D.O.O.- DYV202000000324		
NAME OF PRODUCT				
TYPE OF VALVE		Wafer Tip Kelebek Vana		
NOMINAL DIAMETER (DN) mm		DN 150 DN 065 DN 080		
NOMINAL PRESSURE (PN) bar		16 BAR		
STANDARD / DESIGN		TS EN 593		
END CONNECTION		TS EN 1092-2		
QUANTITY		32		
Nominal Diameter		QUANTITY		
DN 150		12 PCS		
DN 065		10 PCS		
DN 080		10 PCS		
SPECIFICATION OF MATERIALS				
Body	ENJS 1030 (GGG40)	Gasket	EPDM-NBR	
Disc	EN JS 1030 (GGG 40) + NICKEL PLATED	Stem Bearing	LUBRICATED BRONZE	
Lever	EN JS 1030 (GGG 40)			
Top Stem	AISI 420 (STAINLESS STELL)			
Bottom Stem	AISI 420 (STAINLESS STEEL)			
EPDM	EPDM			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
C	Mn	Si	P	S
3,72	0,12	2,45	0,005	0,012
INSIDE CLEANING				
PAINTING&COLOR	OK			
END COVER	BLUE			
MARKING	OK			
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE MANAGER / Levent GÜNAYDIN		