



QUALITY CERTIFICATE EN 10204 / 3.1

REPORT NO

DATE

7.04.2023

CLIENT

P.V.F. TRADERS D.O.O.-
DYV2023000000154

NAME OF PRODUCT

TYPE OF VALVE

BALL VALVE

NOMINAL DIAMETER (DN) mm

DN 100

NOMINAL PRESSURE (PN) bar

PN 16

STANDARD / DESIGN

TS 3148, EN ISO 17292

END CONNECTION

BS EN 1092-2

QUANTITY

30

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

DN 100

30 PCS

SPECIFICATION OF MATERIALS

Body

EN JL 1040 (GG 25)

O-Ring

EPDM

Flange

EN JL 1040 (GG 25)

Lever

Sı 37 (ÇELİK)

Stem

AISI 420 (STAINLESS
STEEL)

Ball

STAINLESS STEEL

Seals

PTFE

TEST CONDITIONS

TEST LIQUID

WATER

BODY TEST

24 BAR

LEAKAGE TEST

18 BAR

TEST STANDART NO

TS EN 12266-1

TYPICAL CHEMICAL ANALYSIS

C

Mn

Si

P

S

3,12

0,49

2,07

0,045

0,042

INSIDE CLEANING

PAINTING&COLOR

END COVER

MARKING

OK

BLUE

OK

INSPECTOR / Zafer KUYVET

QUALITY ASSURANCE DIRECTOR / Veynel ATILGAN

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZİ MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyar.com e-mail: info@duyar.com

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.
Osmanğazi Mah. 2653 Sok. No:7 Esenyurt/İSTANBUL
Pbx: 444 82 62 Faks: 0 212 355 07 47
Marmara Kurumlar V.D. : 320 003 9012

DUYAR

E.V.F. 20-047