



<b>QUALITY CERTIFICATE</b> <b>EN 10204 / 3.1</b>	REPORT NO			
	DATE	7.04.2023		
	CLIENT	P.V.F. TRADERS D.O.O.- DYV2023000000154		
<b>NAME OF PRODUCT</b>				
TYPE OF VALVE	STATIC BALANCING VALVE			
NOMINAL DIAMETER ( DN ) mm	DN 065			
NOMINAL PRESSURE (PN) bar	PN 16			
STANDARD / DESIGN	TS EN 13789			
END CONNECTION	BS EN 1092-2			
QUANTITY	5			
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 065	5 PCS			
<b>SPECIFICATION OF MATERIALS</b>				
Body	EN JL 1040 (GG 25)			
Bonnet	EN JL 1040 (GG 25)			
Handwheel	EBONITE			
Disc	EN JS 1030 (GGG 40) + RUBBER COATED			
Measurement probe	CuZn40Pb2 (BRASS)			
Stem	AISI 420 (STAINLESS STEEL)			
<b>TEST CONDITIONS</b>				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	18 BAR			
TEST STANDART NO	TS EN 12266-1			
<b>TYPICAL CHEMICAL ANALYSIS</b>				
C	Mn	Si	P	S
3,12	0,45	2,1	0,0433	0,046
INSIDE CLEANING				
PAINTING&COLOR	OK			
END COVER	BLACK			
MARKING	OK			
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE DIRECTOR / Veysel ATILGAN		

DVF 20-047

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRIÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyar.com e-mail: info@duyar.com



DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmangazi Mah. 2653 Sok. No:7 Esenyurt/İSTANBUL

Pbx: 444 82 62 Faks: 0 212 355 07 47

Marmara Kurumlar V.D. : 320 003 9012