



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO			
	DATE	7.04.2023		
	CLIENT	P.V.F.TRADERS D.O.O.- DYV2023000000154		
NAME OF PRODUCT				
TYPE OF VALVE	METAL SEATED GATE VALVE			
NOMINAL DIAMETER (DN) mm	DN 080			
NOMINAL PRESSURE (PN) bar	PN 10			
STANDARD / DESIGN	TS EN 1171			
END CONNECTION	BS EN 1092-2			
QUANTITY	5			
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 080	5 PCS			
SPECIFICATION OF MATERIALS				
Body	EN JL 1040 (GG 25)	Gasket	EPDM	
Bonnet	EN JL 1040 (GG 25)			
Handwheel	EN JL 1040 (GG 25)			
Wedge	EN JL 1040 (GG 25)			
Stem	AISI 420 (STAINLESS STEEL)			
Seats	CuZn40Pb2 (BRASS)			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	15 BAR			
LEAKAGE TEST	11 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
<u>C</u>	<u>Mn</u>	<u>Si</u>	<u>P</u>	<u>S</u>
3,12	0,48	2,08	0,05	0,042
INSIDE CLEANING				
PAINTING&COLOR	OK			
END COVER	BLUE			
MARKING	OK			
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE DIRECTOR / Veysel ATILGAN		

