



QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO			
		DATE		10.09.2020	
		CLIENT		P.V.F.TRADERS D.O.O.- DYV2020000000324	
NAME OF PRODUCT					
TYPE OF VALVE		CHECK VALVE WITH SPRING			
NOMINAL DIAMETER ( DN ) mm		DN 065			
NOMINAL PRESSURE (PN) bar		PN 16			
STANDARD / DESIGN		TS EN 16767			
END CONNECTION		TS EN 1092-2			
QUANTITY		5			
Nominal Diameter		QUANTITY			
DN 065		5 PCS			
SPECIFICATION OF MATERIALS					
Body	EN JL 1040 (GG 25)	Seat	AISI 304 (Stainless Steel)		
Bonnet	EN JL 1040 (GG 25)	Gasket	Klingeit		
Spring	AISI 302 (Stainless Steel)				
Stem DN125..300	AISI 302 (Stainless Steel)				
Stem DN15..100	EN JL 1040 (GG 25)				
Disc	AISI 420 (Stainless Steel)				
TEST CONDITIONS					
TEST LIQUID	WATER				
BODY TEST	24 BAR				
LEAKAGE TEST	18 BAR				
TEST STANDART NO	TS EN 12266-1				
TYPICAL CHEMICAL ANALYSIS					
C	Mn	Si	P	S	
3,1	0,53	2,07	0,04	0,043	
INSIDE CLEANING					
PAINTING&COLOR	OK				
END COVER	BLUE				
MARKING	OK				
INSPECTOR / Zafet KUVVET		QUALITY ASSURANCE MANAGER / Levent GÜNAYDIN			

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyarvalve.com e-mail: info@duyarvalve

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.  
Osmangazi Mh. 2653 Sk. No:7/1 Kırac-Esenyurt / İST.  
Tel: 0212 444 82 62 Fax: 0212 355 07 47  
Marmara Kurumlar V.D.: 320 003 9012  
Mersis No: 0320003901200011